

ALLIANT ENERGY CENTER ENERGY LOSS THRU DOOR OPENING

GIVEN CONDITIONS

FROM 2001 ASHRAE HANDBOOK OF FUNDAMENTALS, PAGE. 26.11,
Eqn. 30, ENERGY FLOW DUE TO THERMAL FORCES:

$$Q = 60 \cdot C_D \cdot A \cdot \sqrt{(2 \cdot g \cdot H_{NPL} \cdot (T_i - T_o) / T_i)}$$

WHERE $C_D = \text{ABS}(T_i - T_o) \cdot 0.0025 + 0.4$

(IN Eqn. 30, IF $T_o > T_i$, SUBSTITUTE $(T_o - T_i) / T_o$)

CALCULATIONS ASSUME THAT THE DOOR IS OPENED MAINLY BETWEEN 8 AM AND 4 PM, 2 Day/Wk, FOR APPROXIMATELY 696 HOURS PER YEAR.
THE CALCULATIONS ALSO ASSUME NO SAVINGS BETWEEN 50 °F AND 60 °F DUE TO ECONOMIZER OPERATION. THE CALCULATION PROCESS
FIRST DETERMINES FROM BIN DATA THE NUMBER OF HOURS IN EACH 5 DEGREE BIN. THEN HEATING AND COOLING ENERGY IS CALCULATED.

g = 32.2 ft/sec²
A = 224 ft²
H_{NPL} = 10 ft
T_(WINTER) = 68 °F
T_(SUMMER) = 75 °F
ENTHALPY @ 75 °F & 50% RH = 28.1 BTU/#_M

HOURS ADJUSTMENT

BIN TEMP., °F		ADJUSTED HOURS, 2 Days/Wk 8am - 4pm	ADJUSTED TO 374 HOURS
97.5			
92.5		9	5
87.5		30	15
82.5		56	28
77.5		73	37
72.5		73	37
67.5		64	32
62.5		56	28
57.5		46	*
52.5		41	*
47.5		44	22
42.5		46	23
37.5		60	30
32.5		69	35
27.5		57	29
22.5		38	19
17.5		25	13
12.5		19	10
7.5		13	7
2.5		8	4
-2.5		4	2
-7.5		2	1
-12.5		0	0
-17.5		0	0
-22.5		0	0
		833	374

* HOURS NOT INCLUDED DUE TO ECONOMIZER OPERATION

GENERAL CALCULATIONS

C _D	Q, CFM
0.44	73,109
0.43	60,048
0.42	45,164
0.41	25,297
0.41	25,297
0.42	45,164
0.43	60,048
ECONOMIZER OPERATION	
0.45	84,505
0.46	96,859
0.48	108,786
0.49	120,445
0.50	131,938
0.51	143,333
0.53	154,677
0.54	166,005
0.55	177,343
0.56	188,710
0.58	200,121
0.59	211,589
0.60	223,121
0.61	234,727
0.63	246,411

HEATING CALCULATION

	MBH	MBH/YR
4		
3		
2		
1		
1		
2		
3		
ECONOMIZER OPERATION		
4	1,871	41,269
5	2,668	61,515
6	3,583	107,786
6	4,618	159,737
7	5,771	164,907
7	7,043	134,177
8	8,436	105,729
8	9,950	94,778
9	11,588	75,518
10	13,349	53,538
10	15,237	30,555
11	17,253	17,298
11	19,398	0
12	21,675	0
13	24,084	0

1,046,809
@ 80% EFFICIENCY =

13,085 THERMS

\$0.65 Therm Rate
\$8,439.90

AIR CONDITIONING CALCULATION

COINCIDENT ENTHALPY, 8am - 4 pm	MBH	MBH/YR
40.3	4,014	18,109
37.9	2,648	39,826
34.3	1,260	35,376
31.5	387	14,165
29.2	125	4,583
25.7	488	15,650
22.5	1,513	42,481
ECONOMIZER OPERATION		

170,190
@ 12,000 BTUs/TON & 0.8 kW/TON =

11,346 kWh

\$0.14 kWh Rate
\$1,531.71

BIN HRS Madison, WI 2 Days/Wk 8am - 4 pm

Deg	BIN HR
97	6
92	9
87	30
82	56
77	73
72	73
67	64
62	56
57	46
52	41
47	44
42	46
37	60
32	69
27	57
22	38
17	25
12	19
7	13
2	8
-3	4
-8	2
-13	0
-18	0
-23	0
-28	0
	839

\$9,971.61 Combined Annual Savings

\$83,500.00 Project Cost

8.37 Payback Period