



# Dane County Planning & Development

## Land Division Review

---

Date: July 11, 2017

To: Zoning & Land Regulation Committee

From: Daniel Everson, Land Division Review

Re: Cherry Wood Ridge (preliminary plat)  
Town of Middleton, Section 29 & 30  
(23 residential lots and 5 outlots, 32.4 acres)  
Current Zoning District – A-1  
*Review deadline – September 19, 2017*

Staff recommends the following conditions that will be applicable in accepting the preliminary plat and schedule for future consideration.

1. Compliance with the Dane County Comprehensive Plan is to be established.
  - *See attached memo from Planner Curt Kodl*
2. The public park land appropriation requirement is to be satisfied.
  - *All outlots are proposed as dedicated to the public either for stormwater management and recreational purposes.*
3. All streets shall be noted as dedicated to the public.
4. Outlot 5 does not meet the minimum frontage along a public road.
  - *Committee's discretion with regards to requiring a waiver from Ch. 75.19(6)(b) or a note added to the plat prohibiting any type of development.*
5. Utility easements are to be provided.
6. Grading and surfacing. All streets shall be graded and surfaced in accordance with plans, specifications and requirements of the Dane County Highway Commission and the Town of Middleton.
7. Compliance with Ch. 14.45 DCCO, Erosion Control Plans is to be established.
8. Compliance with Ch. 14.46 DCCO, Stormwater Control Permits is to be established.
  - *A stormwater permit is required and new development standards must be met.*

9. The required approval certificates are to be satisfied.

- *Town of Middleton*
- *Dane County*